



Bruhat Bengaluru Mahanagara Palike

MEDICAL OFFICER OF HEALTH RR NAGAR ZONE BENGALURU-560098


No.BBMP/MOH/RRN/PR/05/2024-2025

Date: 15-06-2024

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Dr. Dayanada G.R, Medical officer of health and S.H.I Nagarajaiah BBMP health department BBMP Inspected the **ORCHIDS THE INTERNATION SCHOOL**, No. 358, RHCS Srigandada kaval, Annapoorneshwari nagar, 11th cross, 60 ft road, Nagarabhavi 2nd stage, Bangalore-560091. On 30-04-2024 checked the water test report submitted by the school and found that the **ORCHIDS THE INTERNATION SCHOOL** as potable drinking water for student and staff of the institution and is having provision for running water in the toilet and maintaining hygienic sanitation condition in the school building and the campus as per the norms prescribed by the central /state U.T Government.

The above is valid for a period of 30-04-2025

Signature with Seal: 
Name : Dr. Dayananda G.R
Designation : Medical Officer of Health

To
ORCHIDS THE INTERNATION SCHOOL,
No. 358 RHCS Srigandada kaval
Annapoorneshwari nagar, 11th cross
60 ft road Nagarabhavi 2nd stage
Bangalore-560091.

Advice:

1. Sample.....
Need effective chlorination before use
2. Sample.....
Need to avoid possible source of faecal contamination and effective chlorination before use
For the purpose of chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WAPPPTER

		Presumptive Coliform count per 100ml	E coli count per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

No:PHI/Water/BAC/1005/24-25

GOVERNMENT OF KARNATAKA


Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Report of Bacteriological analysis of Water/Effluent sample

Dated: 13/06/24

Sample No.	Source & Particulars of Water Sample	Opinion							
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P	N.S.P.P & FC.		
10	Oxhida The International School Naggesarbhavi.	2176	RO water	NIL	-	-	SPP	-	-

Note:
M.P.N Count:
Most probable number of Bacteria per 100ml of Water
D.C Test:
Differential Coliform test
Plate Count:
Plate Count per ml of sample
SPP:
Water is satisfactory for Potable purpose
NSPP:
Water is not satisfactory for Drinking purpose
NSPP & FC:
Water is not satisfactory for Drinking purpose and E.Coli found



For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)